

From Fire Station Officer

Fire Station Thanesar

To M/s Ms HINDU HIGH SCHOOL

Ladwa Distt Kurukshetra Haryana

Memo No. FS/2022/17 dated : 02/07/2022

Subject : Approval of fire fighting scheme Under 15 mtrs. from the fire safety point of view for Group B- Educational Building at Plot Area 11169.32 Sq Mtrs Plot Area Ladwa Distt Kurukshetra Haryana of M/s HINDU HIGH SCHOOL :

Reference your Transaction Id 110702223000022 dated: 17/06/2022 on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Thanesar, .The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines. Therefore your proposed fire fighting scheme is hereby approved as per following detail from the fire safety point of view with the following conditions:-

Tower Name	Floor Detail	Terrace Height of Last Livable Floor(In Meters)	Ground Coverage
Block - 1	Ground Floor	4.268 Mtrs	542.968 Sq Mtrs
Block - 2	Ground Floor	4.268 Mtrs	508.709 Sq Mtrs
Block - 3	Ground Floor	4.268 Mtrs	333.599 Sq Mtrs
Tower Name	Basement Level	Basement Area	Basement Remarks
	Nil	Nil	.

- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un- noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.
- 7) The staircase shall be made with the specified material enabling it non-slippery.
- 8) The above Fire Fighting Scheme is valid for Two Year from the date of issue of this letter.
- 9) If the gap between ceiling and false ceiling is more than 800 mm then upright sprinkler and detectors above false ceiling & pendent sprinkler below false ceiling shall be installed in the building

Remarks:- Application Updated



ADFO (KURUKSHETRA)

Fire Station Thanesar

Exercising the power of Director, Fire Services, Haryana



Digitally signed by Ram Singh
Date: 2022.07.02 11:23:57
+05:30
Reason: Digital Verification